

DISTRICT WATER TESTING LABORATORY, SBS NAGAR

District Water Testing Laboratory, Department of Water Supply and Sanitation, Village Saloh, SBS
Nagar, Punjab
dwtsbs@gmail.com

To,

Scholar Public High School Ladhana Ucha
Scholar Public High School Ladhana Ucha, SBS Nagar

No.: DWTSBS/2526/00232 Dated : 09/02/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Ref No. S/P/S 4901 Dated: 05/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 05/02/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, SBS Nagar

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
SBS Nagar

Chairman
Scholar Public High School
Ladhana Ucha, (S.B.S. Nagar)



TC-14062

TEST REPORT

Name & Address of Customer : Scholar Public High School Ladhana Ucha Scholar Public High School Ladhana Ucha, SBS Nagar		Customer Reference No.	No : Ref No. S/P/S 4901 Dated : 05/02/2026
		Sample Submitted by	Mr. Ram Singh
		Date of Sample Receipt	05/02/2026
		Analysis Starting Date	06/02/2026
		Analysis completion Date	07/02/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC988126000000034F	Sample Type :	Water
Test Report No.:	DWTLSBS/2526/00232	Date of Issue :	09/02/2026
Registration no.:	DWTLSBS/REG2526/01207	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Scholar Public High School Ladhana Ucha (R.O) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Banga	District :	SBS Nagar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.56@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	59	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	19	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	32	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	6.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	3.88	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	4	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA= Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Kulinder Singh
Chairman
Scholar Public High School
Ladhana Ucha, (S.B.S. Nagar)

Mr. Davinder Singh
Chemist/Analyst
Authorized Signatory
For, District Water Testing Laboratory
SBS Nagar